



# INSPECTOR'S DAILY REPORT

City of Lake Forest Park - Staunton Cove Short Plat

Daily Information	
Inspector's Name:	Michael Maranan <span style="float: right;">Date: 10/14/2016</span>
Inspector's Shift Hours:	8 a.m. to 5 p.m. - Periodic
Weather:	a.m.: 52±°F, rain p.m.:
Prime Contractor:	Universal Land Construction Company
Representative & Title:	Mike Johnson, Project Manager
Contractor's Work Activity	
Location of Work:	Site (18623 40th Place NE)
Description of Work:	Temporary Erosion and Sedimentation Control (TESC) Best Management Practices (BMPs)

Inspection			
Time	What was inspected?	In Conformance?	Comments / Action
-	TESC BMPs	-	<ul style="list-style-type: none"> <li>No work - street frontage was clean</li> <li>Stockpiles and exposed areas were fully covered.</li> <li>The temporary sediment pond overtopped; however, the surface flows still end up getting infiltrated onsite.</li> </ul>

Inspection	
Diary	
Time	Discussion
10:30 AM - 11:10 AM	<p>Approximate time of arrival on site was 10:30 AM. No one was on site.</p> <p>The following TESC items have been noted:</p> <ol style="list-style-type: none"> <li><b>Discharge:</b> No discharge. Approximate amount of precipitation since last inspection: <u>1.2±</u> inch* Approximate amount of precipitation in the past 24 hours: <u>1.2±</u> inch* * Based on nearby rain gauge as recorded by King County.</li> <li><b>Construction Entrance:</b> OK.</li> <li><b>Perimeter protection:</b> OK.</li> <li><b>Tree protection:</b> OK.</li> <li><b>Silt fence:</b> OK.</li> <li><b>Inlet protection:</b> OK.</li> <li><b>Stabilization of exposed soils:</b> OK.</li> <li><b>Dust control:</b> OK.</li> <li><b>Source control:</b> See concerns raised in yesterday's report.</li> </ol>

Michael Maranan  
(Inspector's Printed Name)

Signature

10/14/2016  
Date

## City of Lake Forest Park - Staunton Cove Short Plat

Subject: [Storm Drainage Construction](#)

Location: [Site](#)

Comment:

- (1) Exposed areas covered.
- (2) Check dam for the temporary sediment trap's outlet channel.



(1)



(2)